4/17/22, 1:35 PM Print

PRODUCT SPECIFICATIONS FOR P50-4

GENERATOR SET SPECIFICATIONS

Minimum Rating45 kVA / 36 kWMaximum Rating50 kVA / 40 kWEmissions/Fuel StrategyFuel Optimised50 Hz Prime45 kVA / 36 kW50 Hz Standby50 kVA / 40 kW

 60 Hz Prime
 - /

 Frequency
 50 Hz

 Speed
 1500 RPM

 Voltage
 220-415 Volts

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload

power for 1 hour in 12 hours.

These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings. The alternator on this model is peak continuous rated (as defined

in ISO 8528-3).

Standard reference conditions 25 C (77 F)
Air Inlet Temp, 100m (328 ft) A.S.L. 30%
relative humidity. Fuel consumption data at full
load with diesel fuel with specific gravity of
0.85 and conforming to BS2869: 1998, Class

A2.

50 Hz Standby Rating

50 Hz Prime Rating

60 Hz Prime Rating

ENGINE SPECIFICATIONS

Engine Model Perkins® 1103C-33TG2/3

Bore 105 mm (4.1 in)
Stroke 127 mm (5 in)
Governor Type Mechanical

Displacement 3.3l (201.4 cu. in)

Compression Ratio 18.23:1

P50-4 STANDARD EQUIPMENT

4/17/22, 1:35 PM Print

ENGINE

- Air Cleaner
- · Lube oil drain valve
- Engine filled with lubrication oil
- High Coolant Temperature Shutdown
- Low Oil Pressure Shutdown
- · Exhaust stub pipe and gasket

COOLING

- Radiator & Cooling Fan
- Fan,fan drive and battery charging alternator drive fully guarded to meet EC Machinery Directive
- Cooling System filled with Coolant mix
- · Coolant drain valve

EXHAUST

- Exhaust flange outlet
- Exhaust stub pipe and gasket

FUEL

- 8 Hr Fuel Tank
- · Customer connection fuel sockets

ALTERNATOR

- FG Wilson FGL Alternator
- SHUNT Excitation
- IP23 Protection

CONTROL PANEL

DCP-10 / PowerWizard 1.1

MOUNTING

Base, Formed Steel with Single wall Fuel Tank

4/17/22, 1:35 PM Print

- Certified Base Mounted Lifting Eyes, and Rear Drag Eyelets
- · Battery Tray and Cables
- Anti-vibration mounts

P50-4 OPTIONAL EQUIPMENT

EXHAUST

• Industrial, Residential, Critical Silencers

ALTERNATOR

- · Alternator options including 3 Phase sensing, quadrature droop kit and PMG
- Anti-Condensation Heater and Panel Circuitry

CONTROL PANELS

- PowerWizard 1.1+ Control Panel (PWT1.1+)
- PowerWizard 2.1 Control Panel (PWT2.1)

STARTING/CHARGING

Static battery charger with auto boost for lead acid battery

GENERAL

- Upgrade to Standard Set for "CE" Certification
- EEC Declaration of Conformity
- · Narrow, Wide or Skid Base
- Sound attenuated, steel or galvanised enclosure
- Dual wall fuel tanks

ENCLOSURE

- Compliance to European Community Directive 2000/14/EC
- Super sound attenuation for residential areas
- Totally enclosed exhaust silencing system
- Robust and highly corrosion resistant construction